

Emission Test Certificate

Wednesday 21st October 2020

Supplier: Screenwood Australia (432 The Boulevarde, Kirrawee, NSW, 2232, Australia)

Sample Description: EO MR MDF Tongue and Groove lining boards wrapped in Olefin surface technology

Date Tested: October 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p>Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p>EO MR MDF Tongue and Groove lining boards wrapped in Olefin surface technology</p>
<p>Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.016 mg/m²/hr</p>
<p>Formaldehyde Emission Rate Limit: <0.100 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.059 mg/m²/hr</p>
<p><i>We hereby certify that VOC and Formaldehyde emission rate from EO MR MDF Tongue and Groove lining boards is below the limits specified by Green Building Council of Australia, Green Star Interiors requirements.</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Srikanth C. Srivatsa
PhD (Chemical)
Scientific Consultant



Tuan Duong
B.Eng. (Chemical)
Senior Consultant

V2010002